



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1287

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Mohawk

Fred Hauck
20104 NYS Route 3
Watertown, NY 13601

Project / PO Number: N/A
Received: 05/07/2021
Reported: 07/16/2021

Analytical Testing Parameters

Table with 4 columns: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, Collection Date. Values include 53, Drinking Water, J1E1287-01, RF - Client, 05/06/2021 6:50.

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead with result 0.0136.

Table with 4 columns: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, Collection Date. Values include 49, Drinking Water, J1E1287-02, RF - Client, 05/06/2021 6:25.

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead with result 0.00238.

Table with 4 columns: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, Collection Date. Values include 31, Drinking Water, J1E1287-03, RF - Client, 05/06/2021 6:10.

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead with result 0.00108.

Table with 4 columns: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, Collection Date. Values include 88, Drinking Water, J1E1287-04, RF - Client, 05/06/2021 6:10.

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead with result <0.000800.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1287

Client Sample ID: 27	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-05		Collection Date: 05/06/2021 6:05

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00425	0.015 AL	0.000400	mg/L		07/06/21 1957	07/06/21 1957	SEA

Client Sample ID: 91	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-06		Collection Date: 05/06/2021 6:50

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00192	0.015 AL	0.000400	mg/L		07/06/21 1959	07/06/21 1959	SEA

Client Sample ID: 84	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-07		Collection Date: 05/06/2021 6:12

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000406	0.015 AL	0.000400	mg/L		07/06/21 2001	07/06/21 2001	SEA

Client Sample ID: 46	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-08		Collection Date: 05/06/2021 6:20

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00814	0.015 AL	0.000800	mg/L		06/30/21 1544	07/01/21 1828	EMB



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1287

Client Sample ID: 42	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-09		Collection Date: 05/06/2021 6:18

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00331	0.015 AL	0.000400	mg/L		07/06/21 2005	07/06/21 2005	SEA

Client Sample ID: 85	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-10		Collection Date: 05/06/2021 6:17

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/06/21 2007	07/06/21 2007	SEA

Client Sample ID: 47	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-11		Collection Date: 05/06/2021 6:30

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/06/21 2008	07/06/21 2008	SEA

Client Sample ID: 61B	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-12		Collection Date: 05/06/2021 7:00

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/06/21 2010	07/06/21 2010	SEA



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1287

Client Sample ID: 95	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-13		Collection Date: 05/06/2021 7:15

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/06/21 2012	07/06/21 2012	SEA

Client Sample ID: 72B	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-14		Collection Date: 05/06/2021 7:15

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/06/21 2023	07/06/21 2023	SEA

Client Sample ID: 68	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-15		Collection Date: 05/06/2021 7:15

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/06/21 2025	07/06/21 2025	SEA

Client Sample ID: 72	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-16		Collection Date: 05/06/2021 7:18

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/06/21 2027	07/06/21 2027	SEA



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1287

Client Sample ID: 73	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-17		Collection Date: 05/06/2021 7:15

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/06/21 2030	07/06/21 2030	SEA

Client Sample ID: 62	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-18		Collection Date: 05/06/2021 7:05

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000800	0.015 AL	0.000800	mg/L		06/30/21 1544	07/01/21 1830	EMB

Client Sample ID: 94	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-19		Collection Date: 05/06/2021 7:20

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/06/21 2032	07/06/21 2032	SEA

Client Sample ID: 97	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-20		Collection Date: 05/06/2021 7:20

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/06/21 2034	07/06/21 2034	SEA



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1287

Client Sample ID: 34	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-21		Collection Date: 05/06/2021 6:11

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/06/21 2036	07/06/21 2036	SEA

Client Sample ID: 32	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-22		Collection Date: 05/06/2021 6:10

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/06/21 2038	07/06/21 2038	SEA

Client Sample ID: 76	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-23		Collection Date: 05/06/2021 7:30

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/06/21 2040	07/06/21 2040	SEA

Client Sample ID: 74	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-24		Collection Date: 05/06/2021 7:15

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/06/21 2052	07/06/21 2052	SEA



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1287

Client Sample ID: 35	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-25		Collection Date: 05/06/2021 6:05

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000547	0.015 AL	0.000400	mg/L		07/06/21 2100	07/06/21 2100	SEA

Client Sample ID: 74B	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-26		Collection Date: 05/06/2021 7:15

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/06/21 2101	07/06/21 2101	SEA

Client Sample ID: 28	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-27		Collection Date: 05/06/2021 6:05

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00193	0.015 AL	0.000800	mg/L		07/07/21 1429	07/12/21 1928	SEA

Client Sample ID: 26	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-28		Collection Date: 05/06/2021 6:05

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000584	0.015 AL	0.000400	mg/L		07/06/21 2103	07/06/21 2103	SEA



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1287

Client Sample ID: 37	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-29		Collection Date: 05/06/2021 6:10

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00179	0.015 AL	0.000400	mg/L		07/06/21 2105	07/06/21 2105	SEA

Client Sample ID: 35	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-30		Collection Date: 05/06/2021 6:10

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000656	0.015 AL	0.000400	mg/L		07/06/21 2112	07/06/21 2112	SEA

Client Sample ID: 39	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-31		Collection Date: 05/06/2021 6:17

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/06/21 2114	07/06/21 2114	SEA

Client Sample ID: 82	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-32		Collection Date: 05/06/2021 6:11

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/06/21 2116	07/06/21 2116	SEA



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1287

Client Sample ID: 30	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-33		Collection Date: 05/06/2021 6:10

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/06/21 2118	07/06/21 2118	SEA

Client Sample ID: 44	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-34		Collection Date: 05/06/2021 6:40

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000844	0.015 AL	0.000400	mg/L		07/06/21 2120	07/06/21 2120	SEA

Client Sample ID: 45	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-35		Collection Date: 05/06/2021 6:18

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00346	0.015 AL	0.000400	mg/L		07/06/21 2123	07/06/21 2123	SEA

Client Sample ID: 48	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-36		Collection Date: 05/06/2021 6:30

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00407	0.015 AL	0.000400	mg/L		07/06/21 2129	07/06/21 2129	SEA



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1287

Client Sample ID: 87	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-37		Collection Date: 05/06/2021 6:35

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000527	0.015 AL	0.000400	mg/L		07/06/21 2131	07/06/21 2131	SEA

Client Sample ID: 43	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-38		Collection Date: 05/06/2021 6:20

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000414	0.015 AL	0.000400	mg/L		07/06/21 2138	07/06/21 2138	SEA

Client Sample ID: 51	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-39		Collection Date: 05/06/2021 6:40

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000635	0.015 AL	0.000400	mg/L		07/06/21 2140	07/06/21 2140	SEA

Client Sample ID: 71	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-40		Collection Date: 05/06/2021 7:20

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/06/21 2142	07/06/21 2142	SEA



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1287

Client Sample ID: 99	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-41		Collection Date: 05/06/2021 7:31

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/06/21 2145	07/06/21 2145	SEA

Client Sample ID: 247	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-42		Collection Date: 05/06/2021 7:30

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000551	0.015 AL	0.000400	mg/L		07/06/21 2147	07/06/21 2147	SEA

Client Sample ID: 21	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-43		Collection Date: 05/06/2021 7:35

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000974	0.015 AL	0.000400	mg/L		07/06/21 2149	07/06/21 2149	SEA

Client Sample ID: 89	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-44		Collection Date: 05/06/2021 6:40

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/06/21 2151	07/06/21 2151	SEA



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1287

Client Sample ID: 20	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-45		Collection Date: 05/06/2021 7:30

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00801	0.015 AL	0.000400	mg/L		07/06/21 2206	07/06/21 2206	SEA

Client Sample ID: 83	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-46		Collection Date: 05/06/2021 6:12

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000714	0.015 AL	0.000400	mg/L		07/06/21 2211	07/06/21 2211	SEA

Client Sample ID: 6	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-47		Collection Date: 05/06/2021 6:02

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/06/21 2213	07/06/21 2213	SEA

Client Sample ID: 40	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-48		Collection Date: 05/06/2021 6:15

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00400	0.015 AL	0.00400	mg/L	D2	06/22/21 1602	06/24/21 1643	SEA



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1287

Client Sample ID: 1	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-49		Collection Date: 05/06/2021 6:00

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00792	0.015 AL	0.000400	mg/L		07/06/21 2217	07/06/21 2217	SEA

Client Sample ID: 2	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-50		Collection Date: 05/06/2021 6:00

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/06/21 2218	07/06/21 2218	SEA

Client Sample ID: 5	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-51		Collection Date: 05/06/2021 6:01

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00393	0.015 AL	0.000400	mg/L		07/06/21 2220	07/06/21 2220	SEA

Client Sample ID: 80	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-52		Collection Date: 05/06/2021 6:05

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/06/21 2222	07/06/21 2222	SEA



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1287

Client Sample ID: 41	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-53		Collection Date: 05/06/2021 6:13

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00133	0.015 AL	0.000400	mg/L		07/06/21 2224	07/06/21 2224	SEA

Client Sample ID: 4	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-54		Collection Date: 05/06/2021 6:01

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0185	0.015 AL	0.000400	mg/L		07/06/21 2231	07/06/21 2231	SEA

Client Sample ID: 3	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-55		Collection Date: 05/06/2021 6:00

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00161	0.015 AL	0.000400	mg/L		07/06/21 2233	07/06/21 2233	SEA

Client Sample ID: 29	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-56		Collection Date: 05/06/2021 6:05

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0563	0.015 AL	0.000400	mg/L		07/06/21 2235	07/06/21 2235	SEA



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1287

Client Sample ID: 81	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-57		Collection Date: 05/06/2021 6:08

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/06/21 2242	07/06/21 2242	SEA

Client Sample ID: 75B	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-58		Collection Date: 05/06/2021 7:20

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000791	0.015 AL	0.000400	mg/L		07/06/21 2244	07/06/21 2244	SEA

Client Sample ID: 33	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-59		Collection Date: 05/06/2021 6:11

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/06/21 2246	07/06/21 2246	SEA

Client Sample ID: 75	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-60		Collection Date: 05/06/2021 7:20

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/06/21 2248	07/06/21 2248	SEA



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1287

Client Sample ID: 22	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-61		Collection Date: 05/06/2021 7:35

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0106	0.015 AL	0.000400	mg/L		07/06/21 2249	07/06/21 2249	SEA

Client Sample ID: 19A	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-62		Collection Date: 05/06/2021 7:25

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00930	0.015 AL	0.000400	mg/L		07/06/21 2257	07/06/21 2257	SEA

Client Sample ID: 79	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-63		Collection Date: 05/06/2021 7:30

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/06/21 2259	07/06/21 2259	SEA

Client Sample ID: 56	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-64		Collection Date: 05/06/2021 6:51

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/06/21 2300	07/06/21 2300	SEA



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1287

Client Sample ID: 19B	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 05/06/2021 7:25
Lab Sample ID: J1E1287-65	

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/06/21 2302	07/06/21 2302	SEA

Client Sample ID: 22B	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 05/06/2021 7:35
Lab Sample ID: J1E1287-66	

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000489	0.015 AL	0.000400	mg/L		07/09/21 2251	07/09/21 2251	SEA

Client Sample ID: 24	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 05/06/2021 7:10
Lab Sample ID: J1E1287-67	

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00144	0.015 AL	0.000400	mg/L		07/09/21 2253	07/09/21 2253	SEA

Client Sample ID: 78	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 05/06/2021 7:30
Lab Sample ID: J1E1287-68	

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/09/21 2255	07/09/21 2255	SEA



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1287

Client Sample ID: 23	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-69		Collection Date: 05/06/2021 7:40

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00599	0.015 AL	0.000400	mg/L		07/09/21 2301	07/09/21 2301	SEA

Client Sample ID: 86	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-70		Collection Date: 05/06/2021 6:30

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/09/21 2302	07/09/21 2302	SEA

Client Sample ID: 20A	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-71		Collection Date: 05/06/2021 7:30

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000409	0.015 AL	0.000400	mg/L		07/09/21 2304	07/09/21 2304	SEA

Client Sample ID: 90	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-72		Collection Date: 05/06/2021 6:45

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000688	0.015 AL	0.000400	mg/L		07/09/21 2306	07/09/21 2306	SEA



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1287

Client Sample ID: 60	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-73		Collection Date: 05/06/2021 7:00

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00137	0.015 AL	0.000400	mg/L		07/09/21 2308	07/09/21 2308	SEA

Client Sample ID: 52	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-74		Collection Date: 05/06/2021 6:10

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00337	0.015 AL	0.000400	mg/L		07/09/21 2310	07/09/21 2310	SEA

Client Sample ID: 19	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-75		Collection Date: 05/06/2021 7:25

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/09/21 2318	07/09/21 2318	SEA

Client Sample ID: 20B	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-76		Collection Date: 05/06/2021 7:30

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/09/21 2320	07/09/21 2320	SEA



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1287

Client Sample ID: 100	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-77		Collection Date: 05/06/2021 7:31

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/09/21 2325	07/09/21 2325	SEA

Client Sample ID: 54	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-78		Collection Date: 05/06/2021 6:45

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00372	0.015 AL	0.000400	mg/L		07/09/21 2327	07/09/21 2327	SEA

Client Sample ID: 61	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-79		Collection Date: 05/06/2021 7:00

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000677	0.015 AL	0.000400	mg/L		07/09/21 2329	07/09/21 2329	SEA

Client Sample ID: 50	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-80		Collection Date: 05/06/2021 6:30

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000634	0.015 AL	0.000400	mg/L		07/09/21 2331	07/09/21 2331	SEA



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1287

Client Sample ID: 67	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-81		Collection Date: 05/06/2021 7:10

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00163	0.015 AL	0.000400	mg/L		07/09/21 2333	07/09/21 2333	SEA

Client Sample ID: 92	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-82		Collection Date: 05/06/2021 7:05

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/09/21 2335	07/09/21 2335	SEA

Client Sample ID: 93	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-83		Collection Date: 05/06/2021 7:05

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/09/21 2337	07/09/21 2337	SEA

Client Sample ID: 57	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-84		Collection Date: 05/06/2021 6:52

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00233	0.015 AL	0.000400	mg/L		07/09/21 1339	07/09/21 1339	EMB



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1287

Client Sample ID: 66	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-85		Collection Date: 05/06/2021 7:10

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00160	0.015 AL	0.000400	mg/L		07/09/21 1344	07/09/21 1344	EMB

Client Sample ID: 63	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-86		Collection Date: 05/06/2021 7:05

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000708	0.015 AL	0.000400	mg/L		07/09/21 1346	07/09/21 1346	EMB

Client Sample ID: 96	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-87		Collection Date: 05/06/2021 7:15

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/09/21 1348	07/09/21 1348	EMB

Client Sample ID: 98	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-88		Collection Date: 05/06/2021 7:20

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/09/21 1350	07/09/21 1350	EMB



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1287

Client Sample ID: 55	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-89		Collection Date: 05/06/2021 6:51

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000911	0.015 AL	0.000400	mg/L		07/09/21 1355	07/09/21 1355	EMB

Client Sample ID: 93	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-90		Collection Date: 05/06/2021 7:05

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/09/21 1357	07/09/21 1357	EMB

Client Sample ID: 65	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-91		Collection Date: 05/06/2021 7:10

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00170	0.015 AL	0.000400	mg/L		07/09/21 1359	07/09/21 1359	EMB

Client Sample ID: 70	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1E1287-92		Collection Date: 05/06/2021 7:15

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/09/21 1401	07/09/21 1401	EMB



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1287

Client Sample ID: 73B	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 05/06/2021 7:15
Lab Sample ID: J1E1287-93	

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/09/21 1403	07/09/21 1403	EMB

Client Sample ID: 69	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 05/06/2021 7:15
Lab Sample ID: J1E1287-94	

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000493	0.015 AL	0.000400	mg/L		07/09/21 1405	07/09/21 1405	EMB

Client Sample ID: 63B	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 05/06/2021 7:05
Lab Sample ID: J1E1287-95	

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00116	0.015 AL	0.000400	mg/L		07/09/21 1410	07/09/21 1410	EMB

Client Sample ID: 58	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 05/06/2021 6:52
Lab Sample ID: J1E1287-96	

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015 AL	0.000400	mg/L		07/09/21 1412	07/09/21 1412	EMB

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1287

Definitions

- AL: US EPA Action Level
- D2: Dilution was performed due to insufficient sample.
- mg/L: Milligrams per Liter
- RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories Inc., Pittsburgh Division
 10121
 02-00257

New York State Department of Health
 PA Department of Environmental Protection
 PADEP Accreditation by Rule

Microbac Laboratories, Inc., New York Division
 NY Lab ID No.: 10795

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.***

Reviewed and Approved By:

Chris Long
 Director
 Reported: 07/16/2021 16:31

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice


MNY Workorder # _____

Mohawk

Client Information		Billing/Invoice:	Analysis Requested				Receiving Info (Lab Use Only)		
Name:	Jeff/Lew Boces		Total Lead (EPA 200.8)					Ice: YES NO	
Address:	20104 NYS Route 3								Cooler: YES NO
Contact:	Health/Safety Dept.								Sample Temp:
Phone:	315-779-7000								Cooler Seal: YES NO
Project:									
Quote ID:	Lead Testing	PO#:							Pickup: YES NO
Rush TAT Bus. Days:	<2 2-5 5-7 7-10	Date Req.:							Dropoff: C W
Carbon Copy:	Yes								Accepted? YES NO
Email Results:	Yes	rfilley@boces.com, fhauck@boces.com, lshaw@boces.com							Container Material
Fax Results:	Yes								Container Size (in MI)

Sample Information			Matrix	Number of Containers for Analysis Requested					Preservative	Comments/Field Data
Description/Location	Date	Time	Type							
1	5/6	6:50	DW	1						
2	5/6	6:25								
3	5/6	6:10								
4	5/6	6:10								
5	5/6	6:05								
6	5/6	6:50								
7	5/6	6:12								
8	5/6	6:20								
9	5/6	6:18								
10	5/6	6:17								
11	5/6	6:30								
12	5/6	7:00								
13	5/6	7:15								
14	5/6	7:15								
15	5/6	7:15								
16	5/6	7:18								
17	5/6	7:15								
18	5/6	7:05								
19	5/6	7:20								
20	5/6	7:20								

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE
 PM: Shannon Weeks
 J 1 E 1 2 8 7



Print Name and Company	Date/Time	Comments
Sampled: <i>[Signature]</i>	5/6	
Received: <i>[Signature]</i>	5/7/01 1600	
Received:		

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder # _____

Matt Hawk

Client Information		Billing/Invoice:	Analysis Requested						Receiving Info (Lab Use Only)		
Name:	Jeff/Lew Boces		Total Lead (EPA 200.8)							Ice: YES NO	
Address:	20104 NYS Route 3										Cooler: YES NO
Contact:	Health/Safety Dept.										Sample Temp:
Phone:	315-779-7000										Cooler Seal: YES NO
Project:											
Quote ID:	Lead Testing	PO#:									Pickup: YES NO
Rush TAT Bus. Days:	<2 2-5 5-7 7-10	Date Req.:									Dropoff: C W
Carbon Copy:	Yes										Accepted? YES NO
Email Results:	Yes	rfiley@boces.com, fhauck@boces.com, lshaw@boces.com		Plastic						Container Material	
Fax Results:	Yes				250 ml						Container Size (in MI)

Sample Information				Matrix	Number of Containers for Analysis Requested						Comments/Field Data
Description/Location	Date	Time	Type								
1	34	5:16	6:11	DW	1						
2	32		6:10								
3	76		7:30								
4	74		7:15								
5	35		6:05								
6	74 B		7:15								
7	28		6:05								
8	26		6:05								
9	37		6:10								
10	35		6:10								
11	39		6:17								
12	82		6:11								
13	30		6:10								
14	44		6:40								
15	45		6:18								
16	48		6:30								
17	87		6:35								
18	43		6:20								
19	51		6:40								
20	71		7:20								

Print Name and Company	Date/Time	Comments
Sampled: <i>[Signature]</i>	5/16/19	
Received:		
Received:		

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice
 MNY Workorder # _____

Mattawock

Client Information		Billing/Invoice:	Analysis Requested					Receiving Info (Lab Use Only)	
Name:	Jeff/Lew Boces		Total Lead (EPA 200.8)					Ice:	YES NO
Address:	20104 NYS Route 3							Cooler:	YES NO
Contact:	Health/Safety Dept.							Sample Temp:	
Phone:	315-779-7000							Cooler Seal:	YES NO
Project:								Pickup:	YES NO
Quote ID:	Lead Testing	PO#:						Dropoff:	C W
Rush TAT Bus. Days:	<2 2-5 5-7 7-10	Date Req.:						Accepted?	YES NO
Carbon Copy:	Yes							Container Material	
Email Results:	Yes	rfilley@boces.com, fhauck@boces.com, lshaw@boces.com		Plastic				Container Size (in MI)	
Fax Results:	Yes			250 ml				Preservative	

Sample Information			Matrix	Number of Containers for Analysis Requested					Comments/Field Data
Description/Location	Date	Time	Type						
1	99	731	DW	1					
2	247	730							
3	21	735							
4	89	646							
5	20	730							
6	83	612							
7	6	607							
8	40	615							
9	1	600							
10	2	600							
11	5	601							
12	80	605							
13	41	613							
14	4	601							
15	3	600							
16	29	605							
17	81	608							
18	75B	720							
19	33	611							
20	75	720							

Print Name and Company	Date/Time	Comments
Sampled: <i>[Signature]</i>	5/6/21	
Received:		
Received:		

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder # _____

Mohawk

Client Information				Billing/Invoice:		Analysis Requested						Receiving Info (Lab Use Only)		
Name:	Jeff/Lew Boces					Total Lead (EPA 200.8)							Ice:	YES NO
Address:	20104 NYS Route 3												Cooler:	YES NO
Contact:	Health/Safety Dept.												Sample Temp:	
Phone:	315-779-7000												Cooler Seal:	YES NO
Project:													Pickup:	YES NO
Quote ID:	Lead Testing			PO#:									Dropoff:	C W
Rush TAT Bus. Days:	<2 2-5 5-7 7-10			Date Req.:									Accepted?	YES NO
Carbon Copy:	Yes												Container Material	
Email Results:	Yes			rfillley@boces.com, fhauck@boces.com, lshaw@boces.com			Plastic						Container Size (in MI)	
Fax Results:	Yes						250 ml						Preservative	
						HNO3								
Sample Information				Matrix		Number of Containers for Analysis Requested						Comments/Field Data		
Description/Location	Date	Time	Type											
1	22	735	DW	1										
2	19A	725												
3	79	730												
4	516	651												
5	19B	725												
6	22B	735												
7	24	710												
8	78	730												
9	23	740												
10	816	630												
11	20A	730												
12	90	645												
13	60	700												
14	52	610												
15	19	725												
16	20B	730												
17	100	731												
18	54	645												
19	cel	700												
20	50	630												
Print Name and Company				Date/Time		Comments								
Sampled: <i>[Signature]</i>				5/6										
Received:														
Received:														

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder # _____

MCHAUCK

Client Information				Billing/Invoice:		Analysis Requested						Receiving Info (Lab Use Only)		
Name: Jeff/Lew Boces						Total Lead (EPA 200.8)						Ice: YES NO		
Address: 20104 NYS Route 3												Cooler: YES NO		
Contact: Health/Safety Dept.												Sample Temp:		
Phone: 315-779-7000												Cooler Seal: YES NO		
Project:												Pickup: YES NO		
Quote ID: Lead Testing				PO#:								Dropoff: C W		
Rush TAT Bus. Days: <2 2-5 5-7 7-10				Date Req.:								Accepted? YES NO		
Carbon Copy: Yes												Container Material		
Email Results: Yes rfilley@boces.com, fhauck@boces.com, lshaw@boces.com												Container Size (in MI)		
Fax Results: Yes												Preservative		
Sample Information				Matrix		Number of Containers for Analysis Requested						Comments/Field Data		
Description/Location		Date	Time	Type										
1	697	5/16	710	DW	1									
2	692		705											
3	93		705											
4	57		652											
5	66e		710											
6	663		705											
7	96		715											
8	98		720											
9	55		657											
10	93		705											
11	65		710											
12	70		715											
13	73B		715											
14	69		715											
15	63B		705											
16	58		652											
17														
18														
19														
20														

Print Name and Company		Date/Time	Comments
Sampled: <i>[Signature]</i>		5/16	
Received:			
Received:			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.